



# CE-CERTIFICATE

## **CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw1468\_2020**

According to report N° A2003151.02 and A2003151.04, dated on 26/06/2020 we confirm that the below mentioned item was tested at CENTEXBEL and at CREPIM with reference to EN 15102:2007+A1:2011 – Decorative wall coverings - Roll and panel form.

The item shows

‘EU fire classification C-s1,d0’

‘compliance with migration of heavy metals and specific elements, maximum formaldehyde release and maximum vinyl chloride monomer (VCM) content’

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 15102:2007 +A1:2011 – Decorative wall coverings – Roll and panel form. These products come under the EU CPR 305/2011 directives for product safety.

### **SAMPLE**

**Non-woven backed PVC wall covering**

### **Company**

**DID Co. Ltd**

10F Gungdo Bldg., #278-19 Nonhyun-Dong  
KR-06103 GANGNAM-GU, SEOUL

**South Korea**

Certificate No. jw1467\_2020 is valid until 30/06/2025

Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 1/07/2020

Inge de Witte, PhD  
Certification Manager